



## SERVICE CERTIFICATE

Inspection Dated: 12/02/25

Call Number: 234779

**SMITHS FIRE LLP** have serviced the **Portable Fire Appliances** in accordance with BS 5306:3

Hunts Kart Racing Club Ltd  
The Old Airfield  
Stow Longa  
Kimbolton  
Cambridgeshire  
PE28 0EY

5	6 Litre AFFF Extinguisher	1	9 Litre AFFF Extinguisher
1	6 Litre Wet Chem	9	2 Kg Dry Powder
22	6 Kg Dry Powder	13	9 Kg Dry Powder
1	1m x 1m Fire Blanket	1	1.2m x 1.8m Fire Blanket

### RETAIN THIS CERTIFICATE

your Fire Officer or Insurance Company may wish to see it

Service Technician: Kevin Holmes

As per British Standard requirements you should inspect your Portable Fire Appliances once per month for signs of discharge/lost pressure (where gauge is fitted)/ damage and that it is correctly located.

*NB: service due date is month specific, not day specific*

**\* Please note that the above equipment has been listed with ourselves for an annual service to comply with British Standard Legislation.\***

Smiths Fire LLP, Northfield Point, Cunliffe Drive, Kettering, Northants NN16 9QJ  
01536 484846 sales@smithsfire.com

Registered in England No. OC339948

Posting Time : **19:02**