

Northantsfire

Certificate

NORTHANTS FIRE LTD
17 Osyth Close
Brackmills Ind Est
Northampton
NN4 7DY

Tel: 01604 760600

On 21/11/2024 have serviced the

FIRE APPLIANCES
in accordance with BS 5306:Part 3
as detailed in Inspection Report 34143

WHILTON MILL LIMITED
WHILTON MILL
NR DAVENTRY
NORTHANTS
NN11 2NH

Z HYDROSPRAY.....	2 CO2 EXTINGUISHER..	8
DRY POWDER EXTING.	19 FIRE BLANKET.....	1
Q WATER TYPE.....	5	

Portable fire extinguishers should be checked at least once every month for signs of discharge / lost / pressure / damage / correct location.
Any portable extinguishers that do not conform to the requirements, not found or serviced or any additional extinguishers required to ensure that the level of cover at the detailed premises is at least sufficient and where applicable in accordance with BS5306-8 are detailed in the inspection report. It is the responsible person's obligation under fire legislation to provide appropriate levels of fire fighting equipment at all times.



Signed (for NORTHANTS FIRE LTD)



This certificate should be retained by customer and is issued in conjunction with the inspection report.

17 Osyth Close, Brackmills Industrial Estate, Northampton NN4 7DY
Telephone: (01604) 760600 Email: info@northantsfire.co.uk www.northantsfire.co.uk

Posting Time : **20:48**